

DAILY QUALITY ASSURANCE REPORT

PAGE ____ OF ____

Name of Contractor: Global Engineering

Project Name: Life Safety--Walls

Installation Name: Fort Gordon, GA

Contract-DO Number: 24-0100

Contract Number: DACA01-98-D-0024

Date: Oct 12 , 2000

(USE SEPARATE REPORT FOR Each D.O./P.O)

Comments:

Sealing fire walls inside post office.

Performed random inspections of fire wall penetrations throughout hospital. Very good work observed. I found only two penetrations that were deficient out of aprox a hundred I looked at. The two defective ones were repaired.

Name: Lloyd South
US Army Corps of Engineers
Quality Assurance Representative
Supporting MedCom

Signature:

