

**DAILY QUALITY ASSURANCE REPORT**

PAGE \_\_\_\_ OF \_\_\_\_

Name of Contractor: Global Engineering

Project Name: Life Safety--Walls

Installation Name: Fort Gordon, GA

Contract-DO Number: 24-0100

Contract Number: DACA01-98-D-0024

Date: Oct 17 , 2000

(USE SEPARATE REPORT FOR Each D.O./P.O )

**Comments:**

Installed shunt breakers for the kitchen hoods. Had trouble with one breaker that could not be installed in the desired location due to a damaged screw. Another location for the breaker will have to be found.

Name: Lloyd South  
US Army Corps of Engineers  
Quality Assurance Representative  
Supporting MedCom

Signature:

