

<b>Project:</b> AFIP – Restore HVAC System	
<b>Location of Work:</b> Walter Reed Army Medical Center – Washington, DC	
<b>Name of Contractor:</b> John J. Kirlin, Inc. (SPD)	
<b>Contract Number:</b> DACA87-97-D-0038, <b>Task Order:</b> 43	
<b>Date:</b> 13 November 2003, Thursday	
<b>Weather:</b> Rain	
<b>Temperature:</b>	Minimum: <u>45</u> °F
	Maximum: <u>62</u> °F
<b>Work performed by contractor:</b>	
<ul style="list-style-type: none"> <li>• Installation of Branches and Tie-ins for CW, HW &amp; HWR (HZ &amp; LZ)</li> <li>• Testing of Mains and Branches for HPS, HPR, LPS and LPS-Pure</li> <li>• Installation of Branches and Tie-ins for Vacuum and Compressed Air</li> <li>• Installation of Insulation for HWS, HWR, CHWS, &amp; CHWR</li> <li>• Installation and Testing of Condensate Pump drains</li> <li>• Installation of Seismic bracing</li> <li>• Installation of Valve Tags and Pipe ID</li> <li>• Demolition of Hot Water Heater Generators – South (Steam)</li> </ul>	
<b>Personnel on Site:</b> John J. Kirlin, Inc. (JJK)	
<b>Subcontractors:</b> Kelly Generators, S. B. Construction, JJK-Steamfitters, JJK-Plumbers, TBN	
<b>Superintendent:</b> Wayne Conley, Coakley Williams	
<b>Contractor Quality Control:</b> Rodney Weyant, Project Manager, JJK	
<b>Verbal Instructions/ Discussions with Contractors:</b>	
I. Discussed Progress of Work.	
<b>Significant Equipment on Site:</b> None.	
<b>Deliberate Inspections made by QA Representative:</b> Plumbing – Steam to Water heat Exchanger (Per Dwg. M6.1)	
<b>Punch-list Items:</b> None.	
<b>Safety violations / Corrective measures taken / Discussions:</b>	
<ul style="list-style-type: none"> <li>• "Hard Hat areas are those with potential hazard of head injury: all Construction areas are considered hard hat areas." (Per EM 381-1-1, 05.D.01.a)/ The Contractor immediately placed his Hard Hat on.</li> </ul>	
<b>Coordination with Facility Manager:</b> Continued to coordinate activities with Jerry Lachapelle, AFIP Project Officer.	
<b>Name:</b> Willie L. Smith, Jr. U.S. Army Corps of Engineers, Baltimore District Quality Assurance Representative	<b>Signature:</b> 