

<b>Project:</b> AFIP – Restore HVAC System	
<b>Location of Work:</b> Walter Reed Army Medical Center – Washington, DC	
<b>Name of Contractor:</b> John J. Kirlin, Inc. (SPD)	
<b>Contract Number:</b> DACA87-97-D-0038, <b>Task Order:</b> 43	
<b>Date:</b> 27 October 2003, Monday	
<b>Weather:</b> Partly Cloudy, Rain	
<b>Temperature:</b>	Minimum: <u>43</u> °F
	Maximum: <u>66</u> °F
<b>Work performed by contractor:</b>	
<ul style="list-style-type: none"> <li>• Installation of Branches and Tie-ins for CW, HW &amp; HWR (HZ &amp; LZ)</li> <li>• Installation of Branched and Tie-ins for HPS, HPR, LPS and LPS-Pure</li> <li>• Stainless Steel Piping in B048 (South)</li> <li>• Installation of Mains for Vacuum and Compressed Air</li> <li>• Spot Insulation in B048 and B032</li> <li>• Installation of Branched and Tie-ins for HWS, HWR, CHWS, &amp; CHWR</li> <li>• Installation of wiring for Air Compressors (B093)</li> </ul>	
<b>Personnel on Site:</b> John J. Kirlin, Inc. (JJK)	
<b>Subcontractors:</b> Kelly Generators, S. B. Construction, JJK-Steamfitters, JJK-Plumbers, TBN	
<b>Superintendent:</b> Wayne Conley, Coakley Williams	
<b>Contractor Quality Control:</b> Rodney Weyant, Project Manager, JJK	
<b>Discussions with Contractors:</b>	
I. Progress of Work.	
<b>Significant Equipment on Site:</b> None.	
<b>Deliberate Inspections made by QA Representative:</b> HVAC Piping (Per Dwg M4.2)	
<b>Verbal Instructions/Discussions:</b> Electrical training will be held on 5 November 2003 for the switchgear.	
<b>Punch-list Items:</b> None.	
<b>Safety violations / Corrective measures taken:</b>	
<ul style="list-style-type: none"> <li>• "Persons shall be provided with eye and face protective equipment...when machines or operations present potential eye or face injury from physical, chemical, or radiation agents." (Per EM 381-1-1, 05.B.01)/ The Contractor left the area and returned with Safety Glasses.</li> </ul>	
<b>Coordination with Facility Manager:</b> Continued to coordinate activities with Jerry Lachapelle, AFIP Project Officer.	
<b>Name:</b> Willie L. Smith, Jr. U.S. Army Corps of Engineers, Baltimore District Quality Assurance Representative	<b>Signature:</b> 